



Life's better outside.®

June 27, 2018

ADDENDUM NO. 03

**PROJECT NUMBER: 134234b
GARNER STATE PARK**

SHADY MEADOWS RESTROOM REPLACEMENT

Commissioners

T. Dan Friedkin
Chairman
Houston

Ralph H. Duggins
Vice-Chairman
Fort Worth

Anna B. Galo
Laredo

Bill Jones
Austin

Jeanne W. Latimer
San Antonio

James H. Lee
Houston

S. Reed Morian
Houston

Dick Scott
Wimberley

Kelcy L. Warren
Dallas

Lee M. Bass
Chairman-Emeritus
Fort Worth

Carter P. Smith
Executive Director

NOTICE TO ALL BIDDERS:

This addendum shall be considered part of the Bid Documents and is issued to change, amplify, or delete from or otherwise explain the documents where provisions of this addendum differ from those of the original contract documents. This addendum shall have precedence over the original bid documents and shall govern.

Bidders are hereby notified that they shall incorporate this addendum in their bid, and it shall be construed that the Contractor's bid shall reflect with full knowledge, all items, changes and modifications to the bid documents herein specified.

Bidders are advised to check for updates, addenda issuance, and bid opening date changes at the TPWD Infrastructure Division Website:

http://www.tpwd.state.tx.us/business/bidops/current_bid_opportunities/construction/

RESPONSE to Bidder Question:

Sheet S-2 shows 6 5/8" concrete core (one-sided form), specifying vertical reinforcing as #5 @ 32" OC. There is nothing showing for horizontal reinforcing. Please clarify horizontal reinforcing is desired and verify sizes/spacing for both vertical and horizontal.

Horizontal reinforcing is desired. Construction will require:

- #5 @ 18" OC horizontal reinforcing bars at mid-depth of concrete
- #5 @ 32" OC vertical reinforcing bars, as shown on drawing

BID DATE CHANGE:

Bid date is changed. Bids are now due no later than 2:00PM on July 12, 2018. All other requirements for bid submission contained in the bidding and contracting documents remain unchanged.

BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE CONTRACTOR'S BID FORM.

WARNING: BIDDER'S FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDA MAY RESULT IN REJECTION OF BID.

END OF ADDENDUM NUMBER 03

Sincerely,



NICOLE CHUPKA, Contract Manager
TPWD Infrastructure Division

cc: Greg Thelen, Project Manager
Ben Obregon, Design Manager
Don Hudson, Construction Manager
David Allen, Site Superintendent
Jay Hess, Regional Contact
Earl Spurlock, Inspector